ᓄᓇᕗᒻᒥ ᐆᒻᒪᖅᑯᑏᑦ ᐊᑭᖏᓐᓂᒃ ᕿᒥᕐᕈᔩᑦ ᑲᑎᒪᔨᖏᑦ
UTILITY RATES REVIEW COUNCIL OF NUNAVUT
IGLUIN AULATJUTITIGUN AKITUTILAANGINNUT KATIMAYIIT NUNAVUNMI
CONSEIL D'EXAMEN DES TAUX DES ENTREPRISES DE SERVICE DU NUNAVUT

# *A message from the Utility Rates Review Council (URRC)*

Qulliq Energy Corporation (QEC) has filed an application for approval of a Major Project Permit Application with the Minister Responsible for QEC to replace a generator set (Genset) in the community of Resolute Bay. QEC submitted that the Genset replacement is required to address reliability and capacity issues in the community. QEC stated the project will address its capacity planning criteria, address a unit that is beyond its useful life and address reliability issues related to the unavailability of spare or replacement parts.

QEC is proposing to replace the 320 kW unit G4 with a new higher capacity 500 kW unit. The total cost to complete the Genset replacement is forecast to be $5.953 million. This would result in an estimated $0.59 million increase in the revenue requirement and a 0.29 cent/kWh increase in the territory-wide rates. QEC noted that the project is expected to be completed by the 2028/29 fiscal year, however the rates would not be adjusted until subsequent General Rate Application.

The URRC would like to hear views from residents and businesses respecting this Application.

A copy of the Application is posted on QEC's website at **www.qec.nu.ca** and is available upon request either through the URRC or QEC.

Written submissions regarding the genset replacement application can be made to the URRC.

**The deadline for written submissions is May 22, 2026, 5 p.m. (Eastern Time).**

Submissions can be sent to:
Email: **URRC@gov.nu.ca**

Address: Executive Director for the URRC,
Box 1000, Stn 200, Iqaluit, NU X0A 0H0

*The URRC is an arm's-length council that gives advice to the Government of Nunavut about rates levied by utilities.*